## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No. 7300-1597:103 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: TEPG – US, 91 Technology Drive, Westminster, MA 01441-0001

Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models \*T360-9950, \*T360-9951, \*T360-9952, \*T360-9953, \*T360-9954, \*T360-9955,

> \*T360-9956, 430636, 430637, 430638, 430639,430640, 430641 and 430642 detector bases. The base acts as an interface between the sensor and the MAPNET controller. Units are intended for use with Models \*T360-9050, \*T360-9051, 430631 and 430634 smoke detectors (CSFM Listing No. 7272-1597:104); Model 430632 smoke detector (CSFM Listing No. 7271-1597:108); and Model 430633 heat detector (CSFM Listing No. 7270-1597:102). Models \*T360-9955, \*T360-9956, 430641 and 430642 are only intended for use with Models \*T360-9051 and 430634 smoke detectors. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as detector bases for use with listee's separately listed compatible fire alarm

control units. Refer to listee's Installation Instructions Manual for additional information.

Models \*T360-9954, \*T360-9955, 430639 and 430641 employ a sounder, which is suitable for use as fire alarm audible signaling device. These base/sounders CAN NOT produce the temporal code pattern in accordance with NFPA 72, 1999 Edition. If this temporal code is required, the sounder/base unit must be used with the control unit that

can produce the temporal pattern.

XLF: 7300-0026:217

\*Rev 05-11-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

MAY 11, 2004 Listing Expires June 30, 2004 Date Issued:

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager